

NOTES :

A. THE ASSA ABLOY AUTOMATIC DOOR ACCESSORY PACKAGE:
CAN BE USED FOR ANY SINGLE FIRE DOOR WITH
RATING LABEL "A", "B", "C", "D", OR "E".
IT MAY ALSO BE USED FOR DOUBLE EGRESS FIRE
DOORS WITH RATING LABEL "A", OR "B".
USEAGE FOR SIMULTANEOUS PAIR FIRE DOORS IS
LIMITED TO THOSE WITH RATING LABEL "B", UNLESS
AN (UL. APPROVED) OVERLAPPING ASTRAGAL AND
CO-ORDINATOR ARE USED TO INSURE PROPER CLOSING
AND SEALING.

B. ASSA ABLOY AUTOMATIC FIRE DOOR ACCESSORY PACKAGE
INCLUDES THE FOLLOWING :
ASSA ABLOY SWING DOOR OPERATOR; (CHOOSE ONE).

① 1A. POWER SWING.
1B. SWINGMASTER 900.
1C. SW100.
1D. SW200I.

④ CAUTION LABELS.

C. ACTUATING DEVICES FOR THE FIRE DOOR.
ANY APPROVED MOTION SENSING DEVICE, OR
PUSH PLATE SWITCH (STAINLESS STEEL);
WITH ROUND OR SQUARE PLATE; (CHOOSE ONE) AND WITH
FACE PLAIN OR ENGRAVED "PUSH TO OPEN" (CHOOSE ONE).

D. SAFETY AND HOLD OPEN DEVICES FOR THE FIRE DOOR.
ANY APPROVED SAFETY AND/OR HOLD-OPEN DEVICE
INCLUDING CONTACT SAFETY MATS WITH TRIM AND
THRESHOLDS MAY BE USED.

E. DEPENDING UPON THE FIRE RATING LABEL REQUIRED, THE
FOLLOWING RECOMMENDED UNDERWRITERS LABORATORIES (UL.)
LISTED MANUAL HARDWARE SHOULD BE SPECIFIED.

② UL. LISTED FIRE DOORS AND FRAMES

⑦ UL. LISTED FIRE RATED VERTICAL ROD DEVICES,
ADAMS RITE 3100, 3300, 3600, 3700, AND 3900 SERIES
OR SIMILAR, SURFACE OR CONCEALED.

NOTE:
ACCEPTABLE SUBSTITUTIONS: SARGENT, NORTON OR CORBIN
RUSSWIN

③ HEAT AND SMOKE DETECTOR(S) (WITH 2 NORMALLY
CLOSED CONTACTS) OR A CENTRAL ALARM SYSTEM.
FOR "A" LABEL RATING;

⑤ AUTOMATIC FLUSH BOLTS

⑧ DOOR CO-ORDINATOR FOR SIMULTANEOUS PAIRS.

FOR SINGLE DOORS;

⑥ A UL. LISTED FIRE RATED SURFACE RIM PANIC DEVICE.

⑨ JAMB MOUNTED COMPATIBLE UL. FIRE RATED ELECTRIC STRIKE.

F. THE ARCHITECTURAL HARDWARE SPECIFIER SHOULD VERIFY
THE COMPATABILITY OF ANY OTHER HARDWARE WITH THE
BESAM FIRE DOOR ACCESSORY PACKAGE.

STANDARD FINISH OF OPERATOR HOUSING. :
DARK BRONZE - AA-C23-A44.
CLEAR - AA-C23-A31.
SPECIAL FINISHES ARE AVAILABLE.

NOTE:
ALL DOORS AND RELATED FIRE DOOR HARDWARE BY OTHERS.

DWG NO. 1015877											
DRN BY	MHW	DATE	10/20/16	CHK BY	SS	DATE	10/20/16	REV.	2.0	DATE	1/17/18
<div><div></div><div></div><div></div><div></div><div></div><div></div><div></div></div>											
ASSA ABLOY						<div><div></div><div></div><div></div><div></div></div>					